

IDAHO UNDERGROUND STORAGE TANK  
Permanent Closure Form

Site Owner/Operator: Zilog, Inc.  
Site Address: 2601 11th Ave. N. Ext., Nampa, ID 83651  
Site County: Canyon  
Telephone: (208) 466-4551 Facility ID (Notification) Number: 140007

Tank was previously (☒) Registered (☐) Never Registered

Fire District: Nampa

Local Closure Permit obtained from: Nampa Fire Dept.

Tank Closure Performed By:

Company: SRM, Inc. Telephone: (208) 345-3667

Date of Closure: 10/29 Method of Closure: Removal(☒) In-Place Closure(☐)

If closed in-place, type of fill material used: \_\_\_\_\_

How will old tanks be disposed of? (☒) Scrap (☐) Landfill (☐)

Other(specify) \_\_\_\_\_

Disposal Location: Rocky Mountain Recycling

TANKS CLOSED

Tank ID #	Age	Size	Last Substance Stored
<u>1 Diesel</u>	<u>11</u>	<u>1000gal.</u>	<u>diesel fuel</u>
<u>2 Diesel</u>	<u>6</u>	<u>550gal.</u>	<u>diesel fuel</u>
<u>Solvent</u>	<u>11</u>	<u>500gal.</u>	<u>acetone</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Will tanks be replaced by new underground tanks? Yes (☐) No (☒)

(NOTE: If yes, you need to submit a notification form for the new tanks.)

Site assessment was completed and: (☐) No contamination was found

(☒) Contamination was found -below cleanup levels.

(NOTE: Regional office of the Idaho Bureau of Water Quality should be contacted for assistance if contamination is found. Records of closure must also be maintained at the site and available upon inspector's request for three years after closure).

Inspecting Agency: Nampa Fire

Inspector's Name: [Signature]

(NOTE: This is generally the local fire department. In some instances there may be no inspecting agency).

Owner/Operator Signature: Michael Rosen

Date: 11/27/90

Return completed form to:

UST Coordinator, Water Quality Bureau  
Idaho Department of Health and Welfare  
Division of Environmental Quality  
450 West State St.  
Boise, Idaho 83720  
Phone (208) 334-5845

USEPA SF



1643313